

Food Service Checklist

Name: BChris Urban
School: Sallm School
Room or Area: Kithen Date Completed: 112124
Signature:


Instructions

- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

		*		
	1.	COOKING AREA		
	1a	Determined that local exhaust fans operate properly (note if fans are excessively noisy)	No	N/A
	1b.	Checked for odors near cooking, preparation, and eating areas		
		Ensured that exhaust fans are used whenever cooking, washing dishes, and cleaning		
	1d.	Determined that gas appliances function properly		\Box /
		Verified that gas appliances are vented outdoors		\Box
		Ensured there are no combustion gas or natural gas odors, leaks, backdrafting, or headaches when gas appliances are used		\(\sigma\)
٠.		Ensured that kitchen is clean after use		
	1h.	Checked for signs of microbiological growth in the kitchen, including the upper walls and ceiling (for example, mold, slime, and algae)		
T.	1i.	manufacturer's directions for use, and carefully reviewed the		_/
	1;	method of application		$\mathbf{\underline{\omega}}$
	lj.	Verified the kitchen is free of plumbing and ceiling leaks (signs include stains, discoloration, and damp areas)		
	2.	FOOD HANDLING AND STORAGE		
		Checked food preparation, cooking, and storage areas for signs of insects and vermin (for example, feces or remains)		
	2b.	Stored leftovers in well-sealed containers with no traces of food on outside surfaces		
	2c.	Ensured that food preparation, cooking, and storage practices are sanitary 🗅		
	2d.	Disposed of food scraps properly and removed crumbs		
	2e.	Cleaned counters with soap and water or a disinfectant (according to school policy)	П	
	2f.	Swept and wet mopped floors		
,	3.	WASTE MANAGEMENT		
	3a.	Selected and placed waste in appropriate containers		
	3b.	Ensured that containers' lids are securely closed		
	3c.	Separated food waste and food-contaminated items from other wastes, if possible		
1		Stored waste containers in a well-ventilated area		
	3e.	Ensured that dumpsters are properly located (away from air intake vents, operable windows, and food service doors in relation to	_	_
		prevailing winds)		

4.	DELIVERIES	Ves	No N/A	
	Instructed vendors to avoid idling their engines during deliveries	◘∕		
4c.	Ensured that doors or air barriers are closed between receiving area and kitchen		/ 	

NOTES



- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response requires
 further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Building and Grounds Maintenance Checklist

Name: CR LUNA	
School: SALEM SCHOOL	
Room or Area: Signature: CR Sun	Date Completed: 115/2024

1.	BUILDING MAINTENANCE SUPPLIES	Yes	No	N/A
	Developed appropriate procedures and stocked supplies for spill control			
	Reviewed supply labels	. 💌		
lc.	Ensured that air from chemical and trash storage areas vents to the outdoors	. 🗹		
1d.	Stored chemical products and supplies in sealed, clearly labeled containers			
1e.	Researched and selected the safest products available	. M		
1f.	Ensured that supplies are being used according to manufacturers'			
	instructions	V		
1g.	Ensured that chemicals, chemical-containing wastes, and containers are disposed of according to manufacturers' instructions	X		
1h.	Substituted less- or non-hazardous materials (where possible)	M		
1i.	Scheduled work involving odorous or hazardous chemicals for periods			
	when the school is unoccupied	X		
1j.	Ventilated affected areas during and after the use of odorous or hazardous chemicals	M		
2.	GROUNDS MAINTENANCE SUPPLIES			
2a.	Stored grounds maintenance supplies in appropriate area(s)			
	Ensured that supplies are used and stored according to manufacturers' instructions			
2ċ	Established and followed procedures to minimize exposure to fumes			
20.	from supplies	M		
2d.	Reviewed and followed manufacturers' guidelines for maintenance			
	Replaced portable gas cans with low-emission cans		X	
2f.	Stored chemical products and supplies in sealed, clearly-labeled			
	containers	X		
2g.	Ensured that chemicals, chemical-containing wastes, and containers are			
	disposed of according to manufacturers' instructions	×		
3.	DUST CONTROL			
3a.	Installed and maintained barrier mats for entrances	M		
3b.	Used high efficiency vacuum bags	M	X	
	Used proper dusting techniques			
3d.	Wrapped feather dusters with a dust cloth			
3e.	Cleaned air return grilles and air supply vents	Ø		

4.	FLOOR CLEANING	s No	NI/A
4a		-	
4b	1 1 1 ()		
4c.	Performed restorative maintenance (as necessary)		
5.	DRAIN TRAPS		
	Poured water down floor drains once per week (about 1 quart of water)		
	Ran water in sinks at least once per week (about 2 cups of water)		
Sc.	Flushed toilets once each week (if not used regularly)		
6.	MOISTURE, LEAKS, AND SPILLS		
6a.	Checked for moldy odors		
6b.	Inspected ceiling tiles, floors, and walls for leaks or discoloration (may indicate periodic leaks)		
6c	Checked areas where moisture is commonly generated (e.g., kitchens,	L	
٠	locker rooms, and bathrooms)		
6d.			
6.	condensate		
oe.	Checked that indoor surfaces of exterior walls and cold water pipes are free of condensate		
6f.	Ensured the following areas are free from signs of leaks and water damage:		
	Indoor areas near known roof or wall leaks		
	Walls around leaky or broken windows		
	Floors and ceilings under plumbing		
	Duct interiors near humidifiers, cooling coils, and outdoor air intakes ⊠		
7.	COMBUSTION APPLIANCES		
7a.	Checked for odors from combustion appliances		
	Checked appliances for backdrafting (using chemical smoke)		
	Inspected exhaust components for leaks, disconnections, or deterioration		
/a.	Inspected flue components for corrosion and soot		
8.	PEST CONTROL		
8a.	Completed the Integrated Pest Management Checklist		

36 - WHELE EQUIPMENT ALLOWS.

50. - MONTHLY OL MORE OFTEN AS REQUIRETO

76 - DIS NOT USE SMORT

NOTES



- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Waste Management Checklist

Name: CR LUNG
School: SALEM SCHOOL


Room or Area: Date Completed: 1/5/2024

Signature: CR Kun C

1.	WASTE MANAGEMENT	FA 1 -	FA II # #
1.		No	N/A
1a.	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids)		
1b.	Ensured that waste containers are lined		
1c.	Ensured that waste from art, science, vocational classes, etc., are		
	handled separately		X
1d.	Labeled recycling bins clearly		
1e.	Ensured number of bins and dumpsters is adequate		
1f.	Ensured appropriate location of dumpsters (i.e., away from air intakes,		
	doors, and operable windows in relation to prevailing winds)		
1g.	Ensured waste containers are emptied regularly		
1h.	Ensured appropriate waste removal schedule		
1i.	Ensured waste is stored in a well-ventilated room		
1j.	Ensured any exhaust fans in the room are operating properly		8
1k.	Checked waste storage areas for odors, contaminants, or signs of vermin		

NOTES

IC - NO SPECIAL WASTES GENERATED. ANY CHEMICAL WASTES ARE DISPOSED OF MW LAWS/REGS. AS NEEDED,




- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 this checklist for
 each ventilation
 unit in your school,
 as well as a
 copy for future
 reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Ventilation Checklist

	Name: CR LOND		
	School: SALEM SCHOOL		
	Unit Ventilator/AHU No: CONSOLIO A TEO REPORT FOR AL		
	Room or Area: Date Completed:	24	
	Signature: CR Lund		
		į.	
	•		
Parent I	OUTDOOR AIR INTAKES		
	example, a fire escape floor plan)	No X	N/A
11	o. Ensured that the ventilation system was on and operating in "occupied" mode		
A	CTIVITY 1: OBSTRUCTIONS		
	Ensured that outdoor air intakes are clear of obstructions, debris, clogs, or covers		
1d	I. Installed corrective devices as necessary (e.g., if snowdrifts or leaves frequently block an intake)		X
A	CTIVITY 2: POLLUTANT SOURCES		
	Checked ground-level intakes for pollutant sources (dumpsters, loading docks, and bus-idling areas)		×
1f.	Checked rooftop intakes for pollutant sources (plumbing vents; kitchen, toilet, or laboratory exhaust fans; puddles; and mist from		
1 or	air-conditioning cooling towers)		
ıg	intakes (e.g., relocated dumpster or extended exhaust pipe)		
A(CTIVITY 3: AIRFLOW		
	Obtained chemical smoke (or a small piece of tissue paper or light plastic) Confirmed that outdoor air is entering the intake appropriately		
2.	SYSTEM CLEANLINESS		
	CTIVITY 4: AIR FILTERS		
	Replaced filters per maintenance schedule		
	blowing downstream)		×
	Vacuumed filter areas before installing new filters.		M
	Confirmed proper fit of filters to prevent air from bypassing (flowing around) the air filter		


2.	SYS I EW CLEANLINESS (continued)				
AC	CTIVITY 5: DRAIN PANS				
2f.	Ensured that drain pans slant toward the drain (to prevent water from accumulating)		No D	N/A	
2g.	Cleaned drain pans				
	Checked drain pans for mold and mildew				
	TIVITY 6: COILS				
21.	Ensured that heating and cooling coils are clean	. 🔼			
	TIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS				
2j.	Ensured that the interior of air-handling unit(s) or unit ventilator				
	(air-mixing chamber and fan blades) is clean				
2k.	Ensured that ducts are clean	×			
	TIVITY 8: MECHANICAL ROOMS				
	Checked mechanical room for unsanitary conditions, leaks, and spills	X			
2m.	Ensured that mechanical rooms and air-mixing chambers are free of trash,				
	chemical products, and supplies	X			
3.	CONTROLS FOR OUTDOOR AIR SUPPLY				
	Ensured that air dampers are at least partially open (minimum position)	X			
3b.	Ensured that minimum position provides adequate outdoor air				
	for occupants				
AC.	TIVITY 9: CONTROLS INFORMATION				
3c.	Obtained and reviewed all design inside/outside temperature and humidity				
	requirements, controls specifications, as-built mechanical drawings,				
	and controls operations manuals (often uniquely designed)				
	TIVITY 10: CLOCKS, TIMERS, SWITCHES				^
3d.	Turned summer-winter switches to the correct position			\mathbf{X} .	- DIGITAL CONTROL
3e.	Set time clocks appropriately				
	Ensured that settings fit the actual schedule of building use (including				
	night/weekend use)	X I			
	TIVITY 11: CONTROL COMPONENTS				
3g.	Ensured appropriate system pressure by testing line pressure at both the				
	occupied (day) setting and the unoccupied (night) setting				THIS APPLIES TO
	Checked that the line dryer prevents moisture buildup			& /	DAZIMATIC CONTROLS.
3i.	Replaced control system filters at the compressor inlet based on the			>	Theomatic controls.
	compressor manufacturer's recommendation (for example, when you blow down the tank)	-n 1		a (NOT APPUCABLE.
	Set the line pressure at each thermostat and damper actuator at the proper	_	_	4	BUILDING 15 DIGITAL
	level (no leakage or obstructions)			X (THIS APPLIES TO PNEUMATIC CONTROLS. NOT APPLICABLE. BUILDING IS DIGITAL CONTROL
A (~11	TIVITY 12: OUTDOOR AIR DAMPERS				
	Ensured that the outdoor air damper is visible for inspection	5 r	7	П	
	Ensured that the recirculating relief and/or exhaust dampers are visible	and le			
	for inspection	бг	7		
	Ensured that air temperature in the indoor area(s) served by each	- 4			
	outdoor air damper is within the normal operating range				
NOT	E: It is necessary to ensure that the damper is operating properly and within	the n	orma	ıl	Chang field Name Section and Advance and A

range to continue.



3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued)					
3n. Checked that the outdoor air damper fully closes within a few minutes of shutting off appropriate air handler		No	N/A		
30. Checked that the outdoor air damper opens (at least partially with no delay) when the air handler is turned on	=				
3p. If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room		100000		34576	
thermostat is set to 85°F	1		45/	Peoples 200	247
position (without completely closing) when the room thermostat is set to 60°F and mixed air thermostat is set to 45°F			1	BUT U	NT
 3r. If the outdoor air damper does not move, confirmed the following items: The damper actuator links to the damper shaft, and any linkage set screws or bolts are tight 	r		X	SET PO	1075
Moving parts are free of impediments (e.g., rust, corrosion)			8		
 Electrical wire or pneumatic tubing connects to the damper actuator					
location, calibrated correctly)					
Proceed to Activities 13–16 if the damper seems to be operating properly.					
ACTIVITY 13: FREEZE STATS					
3s. Disconnected power to controls (for automatic reset only) to test continuity across terminals	(×		
OR 3t. Confirmed (if applicable) that depressing the manual reset button (usually					
red) trips the freeze stat (clicking sound indicates freeze stat was tripped)	(
3u. Assessed the feasibility of replacing all manual reset freeze-stats with automatic reset freeze-stats	Ę				
NOTE: HVAC systems with water coils need protection from the cold. The freeze-staclose the outdoor air damper and disconnect the supply air when tripped. The typic range is 35°F to 42°F.					
ACTIVITY 14: MIXED AIR THERMOSTATS					
3v. Ensured that the mixed air stat for heating mode is set no higher	_	¬	No.		
than 65°F	Ĺ		X		
than the room thermostat setting	C		M		
ACTIVITY 15: ECONOMIZERS					
3x. Confirmed proper economizer settings based on design specifications or local practices]			
NOTE: The dry-bulb is typically set at 65°F or lower.					
3y. Checked that sensor on the economizer is shielded from direct sunlight ■3z. Ensured that dampers operate properly (for outside air, return air,					
exhaust/relief air, and recirculated air), per the design specifications					
NOTE: Economizers use varying amounts of cool outdoor air to assist with the cool load of the room or rooms. There are two types of economizers, dry-bulb and enthal Dry-bulb economizers vary the amount of outdoor air based on outdoor temperature and enthalpy economizers vary the amount of outdoor air based on outdoor temperature and humidity level	ру. е,				

3	. CONTROLS FOR OUTDOOR AIR SUPPLY (continued)					
	CTIVITY 16: FANS					
38	aa. Ensured that all fans (supply fans and associated return or relief fans) that move outside air indoors continuously operate during occupied hours (even when room thermostat is satisfied)					
	OTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as nec usure sufficient outdoor air supply.	essary	to to			
4.	AIR DISTRIBUTION					
	CTIVITY 17: AIR DISTRIBUTION					
4a	Ensured that supply and return air pathways in the existing ventilation system perform as required.					
4b	Ensured that passive gravity relief ventilation systems and transfer grilles between rooms and corridors are functioning					
	OTE: If ventilation system is closed or blocked to meet current fire codes, consult of of the codes is consult of the codes of the code	t with	a			
4c.	Made sure every occupied space has supply of outdoor air (mechanical	_	_			
4d.	system or operable windows)					
NO	OTE: If outlets have been blocked intentionally to correct drafts or discomfort, in discorper the cause of the discomfort and reopen the vents.		ate			
4e.	Modified the HVAC system to supply outside air to areas without an outdoor		· /			
4f.	air supply		_			
	and population changes		×			
4g.	Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents		×			
4h.	Ensured that unit ventilators are quiet enough to accommodate classroom activities		,			
4i.	Ensured that classrooms are free of uncomfortable drafts produced by air					0 -
	from supply terminals	Ä		To	EXTENT	Possible
\mathbb{AC}	TIVITY 18: PRESSURIZATION IN BUILDINGS					
mai	TE: To prevent infiltration of outdoor pollutants, the ventilation system is design intain positive pressurization in the building. Therefore, ensure that the system, is exhaust fans, is operating on the "occupied" cycle when doing this activity.		ng			
4j.	Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, floor joints, pipe openings)	<u>,</u>				
5. I	EXHAUST SYSTEMS					
	TIVITY 19: EXHAUST FAN OPERATION Checked (using chemical smoke) that air flows into exhaust fan grille(s) X					
If fa	ons are running but air is not flowing toward the exhaust intake, check for the fol Inoperable dampers Obstructed, leaky, or disconnected ductwork Undersized or improperly installed fan Broken fan belt	lowing	g:			



5. EXHAUST SYSTEMS (continued)

ACTIVITY 20: EXHAUST AIRFLOW


NOTE: Prevent migration of indoor contaminants from areas such as bathrooms, kitchens, and labs by keeping them under negative pressure (as compared to surrounding spaces).

an	d labs by keeping them under negative pressure (as compared to surrounding sp	oac.	es).		
5b	. Checked (using chemical smoke) that air is drawn into the room from adjacent spaces		No	N/A	
	and outside the room with the door slightly open while checking airflow high and ador opening (see "How to Measure Airflow").	d lo	ow in	ı	
5c.	Ensured that air is flowing toward the exhaust intake	1			
AC	CTIVITY 21: EXHAUST DUCTWORK				
5d.	Checked that the exhaust ductwork downstream of the exhaust fan (which is under positive pressure) is sealed and in good condition	r			
6.	QUANTITY OF OUTDOOR AIR		_		
AC	TIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULATIONS	3		1	v.
NO	TE: Refer to "How to Measure Airflow" for techniques.				
	Measured the quantity of outdoor air supplied (22a) to each ventilation unit	I			
	Calculated the number of occupants served (22b) by the ventilation unit under consideration.				
6c.	Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c) \square				5€€
\mathbb{AC}	TIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTITIES				SNOTE
6d.	Compared the existing outdoor air per person (22c) to the recommended levels in Table 1				(-
6e.	Corrected problems with ventilation units that supplied inadequate quantities of outdoor air to ensure that outdoor air quantities (22c) meet the recommended levels in Table 1				

NOTES

26,20 - MAINTENANCE PERFORMED BY CONTEACTOR

6. - THIS WORK WILL BE COMPLETED BY CONTRACTOR THIS
CALENDAR YEAR DURING STATE MANDATED HVAC/IAQ
INSPECTION.



Walkthrough Inspection Checklist

Name: SACEN SCHOOL C.R. LUND
School: SALEM SCUCOL
Room or Area: Date Completed:Date Completed:

Ins	fra	CT	1	1 C
	FH G			10

- 1. Read the IAQ


 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

1.	GROUND LEVEL	Ves	No	N/A
1a.	. Ensured that ventilation units operate properly			
	. Ensured there are no obstructions blocking air intakes			
	. Checked for nests and droppings near outdoor air intakes			
1d.	Determined that dumpsters are located away from doors, windows, and outdoor air intakes			
1e.	Checked potential sources of air contaminants near the building (chimneys, stacks, industrial plants, exhaust from nearby buildings)	M		
1f.	Ensured that vehicles avoid idling near outdoor air intakes			X
	Minimized pesticide application			
	Ensured that there is proper drainage away from the building (including roof downspouts)			
1i.	Ensured that sprinklers spray away from the building and outdoor air intakes		*	X
1j.	Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly	,		
	they are created regularly			
2.	ROOF			
Whi	ile on the roof, consider inspecting the HVAC units (use the Ventilation Chec	klist)		
2b.	Ensured that the roof is in good condition	. 🗹		
	Ensured that exhaust fans operate properly (air flows out)			
	Ensured that air intakes remain open, even at minimum setting			-
2f.	Checked for nests and droppings near outdoor air intakes			
2g.		. 🔐		
2 5 .	from outdoor air intakes	.🛛		
3.	ATTIC			
3a.	Checked for evidence of roof and plumbing leaks	M		
	Checked for birds and animal nests			
4.	GENERAL CONSIDERATIONS			
4a.	Ensured that temperature and humidity are maintained within acceptable ranges	M		
4b.	Ensured that no obstructions exist in supply and exhaust vents			
	Checked for odors			

4e. 4f.	Checked for signs of water damage	X X	N/A O O	
5a. 5b.	Ensured that bathrooms and restrooms have operating exhaust fans			
6.	MAINTENANCE SUPPLIES			
	Ensured that chemicals are used only with adequate ventilation and when building is unoccupied	K		
	Ensured that vents in chemical and trash storage areas are operating properly	,		
	Ensured that portable fuel containers are properly closed			
7.	COMBUSTION APPLIANCES			
7b. 7c.	Checked for combustion gas and fuel odors			
8.	OTHER			
	Checked for peeling and flaking paint (if the building was built before 1980, this could be a lead hazard)			

NOTES

56 - WATER POULED AS NEEDED OR MONTHLY



- 1. Read the IAQ

 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.


Integrated Pest Management Checklist

				,
	Name: CR LUND			
1	School: SALEN SCHOOL			
	Room or Area: Date Completed: 1/5/20	24	7	
	Signature: Date Completed			
"	originature.			•
_				
1	OFFICIAL POLICY STATEMENT	es I	No	N/A
1a	Developed or located the school's official policy statement for integrated pest management (IPM)			
2.	POLICY 3504,1 LEVISED NOV. 2007 DESIGNATING PEST MANAGEMENT ROLES			
	Assigned and trained a qualified person to be the pest manager			
	Educated students and staff (the occupants of the building) about IPM	9 1		
	and asked them to keep their areas clean and free of clutter		X	
	. Encouraged parents to learn about IPM practices and implement them at home		M	
	Developed a program to educate and train all IPM participants	ı [X.	
2f.	Included language about IPM into contracts with pest management professionals	ı j	X	
3.	SETTING PEST MANAGEMENT OBJECTIVES			
3a.	Set appropriate pest management objectives for school buildings (such as			
	preventing pests from interfering with students' learning environment	, ,	_	
21	and preserving the integrity of the building structure)	Ĺ]	
<i>)</i> 0.	providing safe playing areas and the best athletic surfaces possible)	' (
4.	INSPECTING, IDENTIFYING, AND MONITORING			
1 a.	Inspected all buildings and grounds for pest evidence, entry points, food, water, and harborage sites	Ţ	_	
1b.	Identified potential pest habitats in buildings and grounds	Ç		
ŧс.	Pinpointed the source of any current pest problems			M
	Monitored to determine the extent of pest problems and to estimate pest populations	Ţ		
1e.	Developed plans to modify habitat (for example, exclusion, repair, and sanitation efforts) to prevent or resolve any pest problems	Ţ		A
1f	Established a monitoring program that consists of routine inspections to			

estimate pest population levels and identify evidence of pests and

5.	SETTING ACTION THRESHOLDS			
5a.	Evaluated all available data obtained through inspecting, identifying, and monitoring		No	N/A
5b.	Determined how many pests the school buildings, grounds, and occupants can tolerate			本
5c.				X
6.	PREVENTIVE STRATEGIES			
INI	DOOR SITES			
6a.	Implemented appropriate strategies to prevent pests from inhabiting the following	owing	g area	as:
	• Entryways			
	• Classrooms			
	Gymnasiums	Z		
	Locker rooms	Ø		
	• Offices			
	• Staff lounges	1		
	• Bathrooms			
	• Food preparation and serving areas	Z		
	• Rooms with extensive plumbing	1		
	Maintenance areas	Z		
	• Other	1		
OTT	TDOOR SITES			
	Implemented appropriate strategies to prevent pests from inhabiting the follo	azino	area	g•
<i>.</i>	• Playgrounds			.s.
	• Parking lots			
	• Lawns and athletic fields			
	• Teaching gardens or greenhouses			
	• Loading docks			
	• Dumpsters			
	• Areas with ornamental shrubs and trees	_		
	• Other			
7	PESTICIDE USE AND STORAGE			
	Explored alternative pest management methods before concluding that pesticides were necessary	1		
	Ensured that pest management professionals integrate IPM into their	= '		
	pest management methods	1		
	Identified the least toxic, target-specific chemical (or pesticide			
	formulation) that is the most effective to address the pest problem,			
	preferably as baitsand granules	1		
d.	Reviewed and followed all label instructions on pesticides and learned			
	how to properly apply and handle these chemicals	<u>a</u>		
7е.	Used spot-treatment (or bait, crack, and crevice applications) to apply			
	pesticides whenever possible and only treated the obviously infested			
	plants in the area			
	Used protective clothing or equipment when applying pesticides	1		
₹g.	Placed all pesticides in tamper-resistant bait boxes or locations that are			
	inaccessible to children and non-target species			





7.	PESTICIDE USE AND STORAGE (cont.)			
7h.	runway of the box		No	N/A
7i.	they would not be exposed to the chemicals	1		
7j.	Ensured that school occupants (students and staff) are notified of upcoming pesticide applications through posted notices and/or letters	1		
7k.	Ensured that parents are notified of upcoming pesticide applications through letters	1		
71.	Kept copies of current pesticide labels and information on pesticides easily accessible	1		
	Stored pesticides off site or in areas that are locked and accessible only to designated personnel	1		
7n.	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate the environment	1		
7o.	Ensured that flammable liquids are stored away from ignition sources			
	Ensured that pesticides are stored in their original containers and all lids are securely fastened	1		
7q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system	1		
8.	EVALUATING RESULTS AND RECORD KEEPING			
	Ensured that accurate, up-to-date records of IPM practices and a pest management log for each property are kept		¥	
	Ensured that pesticide records necessary to meet all state, local, and school board requirements are maintained	Ì		X
8c.	Ensured that each log book contains the following items:	1	X	
	• Copy of the pest management plan		M	
	• Current EPA-registered labels			X
	• Current Material Safety Data Sheets (MSDS) for each pesticide project	1		X
	• Pest surveillance data sheets			M
	• Diagram noting the location of pest activity, traps, and bait stations		M	

NOTES

2- APPARENT THAT RE-THAINING /INITIAL TRAINING REQUIRED.
WILL PURSUE DOING SO IAW SPRING STAFF PD.

47- PEST CONTROL BY CONTRACT. - GRIGGS & BLOWNE

7- SELDOM USE PESTICIDES BY SCHOOL STAFF AND THEN ONLY FOR EMERCENCY USE. ONLY USE OVER THE COUNTER PRODUCTS, NOT LICENSED.

Bay 80- NEED TO UIDATE LOGBOOK TO ENSURE CULLENT INFORMATION IS CONTAINED.